CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1574:180 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561

Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Model Unimode 9600 fire alarm control unit. Suitable for non-coded; local, auxiliary,

> proprietary (protected premises and central station (protected premises) when used with appropriate option modules and additional separate listed equipment; automatic manual, waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product

description and operational considerations. System components:

Unimode 9600 Control Unit SLC2 Loop Expander

UDACT-F DACT

Transmission Module 4XTMF Module Bracket BRKT-9600 Dress Panel DP-9600

ACM-8RF Relay Control Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and

in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control panel for use with separately listed compatible initiating and

indicating devices. This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72,

1999. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7165-0085:196

XLF: 7165-0075:191

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 23, 2004 Date Issued: Listing Expires June 30, 2005

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager